

2008 ANNUAL DRINKING WATER QUALITY REPORT

Dillsburg Area Authority PWSID# 7670071

Este informe contiene informacion muy importante sobre su agua de beber. Traduzcalo o hable con alguien que lo entienda bien.

WATER SYSTEM INFORMATION:

Dillsburg Area Authority is pleased to present to you the 2008 Annual Drinking Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

If you have any questions about this report or concerning your water utility, please contact the Authority office at (717) 502-0431, Sheldon Williams, General Manager. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled monthly meetings. They are held at the Authority Office located at 98 West Church Street, Dillsburg Borough on the third Tuesday of each month beginning at 9:30 a.m. Office hours are Monday thru Friday, 7:30 a.m. to 4:00 p.m.

SOURCES OF WATER:

The water provided to the Authority customers in 2008 came from five ground water wells, ranging in depth from 160 feet to 300 feet. Wells No. 1, No. 2, and No. 3 are located in Franklin Township and draw from a Tomstown Formation aquifer. Well No. 4 is located in Carroll Township and draws from a Limestone Fonglomerate aquifer. Well No. 5 is also located in Carroll Township and draws from a Gettysburg Formation aquifer. We have a source water assessment report available from our office that provides more detailed information such as potential sources of contamination. This report is available for viewing upon written request.

Before being delivered to the water distribution system, the water is treated for disinfection and corrosion control. Liquid hypochlorite is added and allowed a minimum of 20 minutes of detention time for disinfection before being delivered to any customer's tap. Caustic soda and polyphosphate are added for corrosion control to reduce leaching of materials from pipes and other water fixtures into the drinking water. These are the only forms of treatment.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

MONITORING YOUR WATER:

Dillsburg Area Authority routinely monitors for contaminants in your drinking water according to federal and state laws. The following tables show the results of our monitoring for the period of January 1 to December 31, 2008. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from

prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table.

DEFINITIONS AND ABBREVIATIONS:

Action Level (AL) – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) – The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) – The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Treatment Technique (TT) – A required process intended to reduce the level of a contaminant in drinking water.

ppm = parts per million, or milligrams per liter (mg/L)

ppb = parts per billion, or micrograms per liter (µg/L)

pCi/L = picocuries per liter (a measure of radioactivity)

DETECTED SAMPLE RESULTS:

Chemical Contaminant	MCL	MCLG	Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Typical Sources of Contamination
Inorganic Contaminants								
Barium	2	2	.044	N/A	ppm	05/2006	N	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Nitrate	10	10	4.36	0.64-4.36	ppm	2008	N	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Disinfection By-Products								
TTHMs [Total trihalomethanes]	80	N/A	12.6	5.4-12.6	ppb	07/2007	N	By-product of drinking water chlorination
Chloroform	N/A	N/A	0.61	0.0-0.61	ppb	07/2006	N	By-product of drinking water chlorination
Bromodichloromethane	N/A	N/A	1.7	0.0-1.7	ppb	05/2005	N	By-product of drinking water chlorination
Chlorodibromomethane	N/A	N/A	0.99	0.0-0.99	ppb	05/2005	N	By-product of drinking water chlorination
Chlorine Residual	MRDL=4	MRDLG=4	1.36	0.89-1.36	ppm	2008	N	Water additive used to control microbes
HAA [Haloacetic acids]	60	N/A	3.2	1.5-3.2	ppb	07/2007	N	By-product of drinking water chlorination

Contaminant	Action Level (AL)	MCLG	90th Percentile Value	Units	# of Sites Above AL of Total Sites		Violation Y/N	Sources of Contamination
Lead	15	0	3.3	ppb	0 out of 20	2007	N	Corrosion of household plumbing systems; erosion of natural deposits
Copper	1.3	1.3	0.112	ppm	0 out of 20	2007	N	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

As you can see by the tables, our system had no violations. We are proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected. The EPA has determined that your water IS SAFE at these levels.

EDUCATIONAL INFORMATION:

The sources of drinking water (both tap water and bottle water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Dillsburg Area Authority
P.O. Box 370
Dillsburg, PA 17019-0370

PRESORTED
FIRST CLASS MAIL
U.S. POSTAGE PAID
DILLSBURG, PA
PERMIT NO. 54

Important information regarding your drinking water.

Attention Landlords: Please provide a copy of this report for your tenants.

Dillsburg Area Authority is committed to providing high quality water and wastewater services through efficiency, planning, and responsiveness to our customers. We ask that all of our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.